

ST PETERS

2014 Annual Water Quality Report

(Consumer Confidence Report)

MO6010719

This report is intended to provide you with important information about your drinking water and the efforts made to provide safe drinking water.

Attencion!

Este informe contiene información muy importante. Tradúscalo o prequentele a alguien que lo entienda bien.

[Translated: This report contains very important information. Translate or ask someone who understands this very well.]

What is the source of my water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Our water comes from the following source(s):

Source Name	Type
WELL # 3, 5, 7, 8, 9, 10, 11, 12, 13	GROUND WATER

Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided below.

Buyer Name	Seller Name
ST PETERS	ST LOUIS CITY

Source Water Assessment

The Department of Natural Resources conducted a source water assessment to determine the susceptibility of our water source to potential contaminants. This process involved the establishment of source water area delineations for each well or surface water intake and then a contaminant inventory was performed within those delineated areas to assess potential threats to each source. Assessment maps and summary information sheets are available on the internet at <http://maproom.missouri.edu/swipmaps/pwssid.htm>. To access the maps for your water system you will need the State-assigned identification code, which is printed at the top of this report. The Source Water Inventory Project maps and information sheets provide a foundation upon which a more comprehensive source water protection plan can be developed.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Contaminants that may be present in source water include:

- A. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- B. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- C. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- D. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- E. Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Department of Natural Resources prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department of Health regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Is our water system meeting other rules that govern our operations?

The Missouri Department of Natural Resources regulates our water system and requires us to test our water on a regular basis to ensure its safety. Our system has been assigned the identification number MO6010719 for the purposes of tracking our test results. Last year, we tested for a variety of contaminants. The detectable results of these tests are on the following pages of this report. Any violations of state requirements or standards will be further explained later in this report.

How might I become actively involved?

If you would like to observe the decision-making process that affect drinking water quality or if you have any further questions about your drinking water report, please call us at **636-278-2221** to inquire about scheduled meetings or contact persons.

Do I need to take any special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Terms and Abbreviations

Population: 51360. This is the equivalent residential population served including non-bill paying customers.

MCLG: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

SMCL: Secondary Maximum Contaminant Level, or the secondary standards that are non-enforceable guidelines for contaminants and may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.

AL: Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow..

TT: Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

90th percentile: For lead and Copper testing. 10% of test results are above this level and 90% are below this level.

Range of Results: Shows the lowest and highest levels found during a testing period, if only one sample was taken, then this number equals the Highest Value.

RAA: Running Annual Average, or the average of sample analytical results for samples taken during the previous four calendar quarters.

LRAA: Locational Running Annual Average, or the locational average of sample analytical results for samples taken during the previous four calendar quarters.

TTHM: Total Trihalomethanes (chloroform, bromodichloromethane, dibromochloromethane, and bromoform) as a group.

HAAs: Haloacetic Acids (mono-, di- and tri-chloroacetic acid, and mono- and di-bromoacetic acid) as a group.

ppb: parts per billion or micrograms per liter.

ppm: parts per million or milligrams per liter.

n/a: not applicable.

NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water.

nd: not detectable at testing limits.



MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

ST PETERS

2014 Annual Water Quality Report

(Consumer Confidence Report)

Contaminants Report

MO6010719

The state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Records with a sample year more than one year old are still considered representative.

Regulated Contaminants

Regulated Contaminants	Collection Date	Highest Value	Range of Results (low – high)	Unit	MCL	MCLG	Typical Source
BARIUM	8/25/2014	0.0296	0.0296	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	8/25/2014	2.07	1.48 - 2.07	ppb	100	100	Discharge from steel and pulp mills
FLUORIDE	8/25/2014	0.61	0.61	ppm	4	4	Natural deposits; Water additive which promotes strong teeth
NITRATE-NITRITE	1/28/2014	0.014	0.014	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TRICHLOROETHYLENE	8/25/2014	0.59	0.59	ppb	5	0	Discharge from metal degreasing sites and other factories

Fluoridation:

In December 2010, the United States Department of Health and Human Services released a report recommending that fluoridation levels in drinking water should be set at 0.7 mg/L. In keeping with this recommendation the City of St. Peters and the City of St. Louis reduced their fluoridation goal to 0.7 mg/L.

The Center for Disease Control (CDC) and the American Dental Association (ADA) have identified that there may be an increase chance of mild dental fluorosis among infants who are exclusively consuming baby formula reconstituted with fluoridated water. For more information, please visit cdc.gov/fluoridation and /or consult with your health care provider.

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range of Results (low/high)	Unit	MCL	MCLG	Typical Source
(HAA5)	DBPDUAL-01	2014	18	11.3 - 23.7	ppb	60	0	Byproduct of drinking water disinfection
(HAA5)	DBPDUAL-02	2014	12	0 - 18.5	ppb	60	0	Byproduct of drinking water disinfection
(HAA5)	DBPDUAL-03	2014	20	12.9 - 24.4	ppb	60	0	Byproduct of drinking water disinfection
(HAA5)	DBPDUAL-04	2014	15	0 - 21.1	ppb	60	0	Byproduct of drinking water disinfection
(HAA5)	DBPDUAL-05	2014	0	0 - 0	ppb	60	0	Byproduct of drinking water disinfection
(HAA5)	DBPDUAL-06	2014	0	0 - 0	ppb	60	0	Byproduct of drinking water disinfection
(HAA5)	DBPDUAL-07	2014	0	0 - 0	ppb	60	0	Byproduct of drinking water disinfection
(HAA5)	DBPDUAL-08	2014	18	0 - 19.5	ppb	60	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-01	2014	13	8.55 - 14.1	ppb	80	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-02	2014	12	0 - 10.6	ppb	80	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-03	2014	15	10.3 - 13.9	ppb	80	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-04	2014	14	4.19 - 13	ppb	80	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-05	2014	2	0 - 0	ppb	80	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-06	2014	2	0 - 0	ppb	80	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-07	2014	3	0 - 0	ppb	80	0	Byproduct of drinking water disinfection
TTHM	DBPDUAL-08	2014	10	4.55 - 13.4	ppb	80	0	Byproduct of drinking water disinfection

Lead and Copper	Date	90th Percentile	Range of Results (low – high)	Unit	AL	Sites Over AL	Typical Source
COPPER	2010 - 2012	0.0126	0.00217 - 0.0354	ppm	1.3	0	Corrosion of household plumbing systems
LEAD	2010 - 2012	1.27	1.06 - 2.16	ppb	15	0	Corrosion of household plumbing systems

Microbiological	Result	MCL	MCLG	Typical Source
COLIFORM (TCR)	In the month of June, 2.90% of samples returned as positive	MCL: Systems that Collect 40 or More Samples per Month - No more than 5% positive monthly samples;	0	Naturally present in the environment

Unregulated Contaminant Monitoring Rule (UCMR)	Collection Date of HV	Highest Value (HV)	Range	Unit
CHLORATE	5/6/2014	130	56 - 130	UG/L
CHROMIUM, HEX	7/24/2013	2.2	1 - 2.2	UG/L
STRONTIUM	3/10/2014	169	169	UG/L
VANADIUM, TOTAL	3/10/2014	1.37	1.37	UG/L

ST PETERS

2014 Annual Water Quality Report

(Consumer Confidence Report)

MO6010719

Violations and Health Effects Information

During the 2014 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Type
No Violations Occurred in the Calendar Year of 2014		

Special Lead and Copper Notice:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ST PETERS is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://water.epa.gov/drink/info/lead/index.cfm>.

You can also find sample results for all contaminants from both past and present compliance monitoring online at the Missouri DNR Drinking Water Watch website <http://dnr.mo.gov/DWW/indexSearchDNR.jsp>. To find Lead and Copper results for your system, type your water system name in the box titled Water System Name and select *Find Water Systems* at the bottom of the page. The new screen will show you the water system name and number, select and click the *Water System Number*. At the top of the next page, under the *Help* column find, *Other Chemical Results by Analyte*, select and click on it. Scroll down alphabetically to Lead and click the blue Analyte Code (1030). The Lead and Copper locations will be displayed under the heading *Sample Comments*. Scroll to find your location and click on the *Sample No.* for the results. If your house was selected by the water system and you assisted in taking a Lead and Copper sample from your home but cannot find your location in the list, please contact ST PETERS for your results.

Reseller Contaminants

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low – high)	Unit	MCL	MCLG	Typical Source
ATRAZINE	6/2/2014	ST LOUIS CITY	0.58	0 - 0.58	ppb	3	3	Runoff from herbicide used on row crops
BARIUM	5/28/2014	ST LOUIS CITY	0.024	0.0231 - 0.024	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	2/3/2014	ST LOUIS CITY	1.2	1.07 - 1.2	ppb	100	100	Discharge from steel and pulp mills
FLUORIDE	5/28/2014	ST LOUIS CITY	0.6	0.58 - 0.6	ppm	4	4	Natural deposits; Water additive which promotes strong teeth
NITRATE-NITRITE	5/20/2014	ST LOUIS CITY	0.69	0.59 - 0.69	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Water System	Highest LRAA	Range (low – high)	Unit	MCL	MCLG	Typical Source
(HAA5)	2014	ST LOUIS CITY	25	13.4 - 33.01	ppb	60	0	Byproduct of drinking water disinfection
TTHM	2014	ST LOUIS CITY	19	4.44 - 30.6	ppb	80	0	Byproduct of drinking water disinfection

Reseller Violations and Health Effects Information

During the 2014 calendar year, the water system(s) that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2014				

ST PETERS
2014 Annual Water Quality Report
(Consumer Confidence Report)

MO6010719

Optional Monitoring (not required by EPA)
Optional Contaminants

Monitoring is not required for optional contaminants.

Secondary Contaminants	Collection Date	Your Water System Highest Value	Range (low - high)	Unit	SMCL
ALKALINITY, CaCO3 STABILITY	8/25/2014	93.7	93.7	MG/L	
ALUMINUM	8/25/2014	0.0131	0.0131	MG/L	0.05
CALCIUM	8/25/2014	29.8	29.8	MG/L	
CHLORATE	5/6/2014	130	56 - 130	UG/L	
CHLORIDE	8/25/2014	142	142	MG/L	250
CHROMIUM, HEX	7/24/2013	2.2	1 - 2.2	UG/L	
HARDNESS, CARBONATE	8/25/2014	163	163	MG/L	
MAGNESIUM	8/25/2014	21.6	21.6	MG/L	
MANGANESE	8/25/2014	0.00887	0.00887	MG/L	0.05
PH	8/25/2014	8.23	8.23	PH	8.5
POTASSIUM	8/25/2014	2.58	2.58	MG/L	
SODIUM	8/25/2014	82.8	82.8	MG/L	
STRONTIUM	3/10/2014	169	169	UG/L	
SULFATE	8/25/2014	57.8	57.8	MG/L	250
TDS	8/25/2014	409	409	MG/L	500
VANADIUM, TOTAL	3/10/2014	1.37	1.37	UG/L	
ZINC	8/25/2014	0.00167	0.00167	MG/L	5

Reseller Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low - high)	Unit	SMCL
1,4-DIOXANE	1/22/2013	ST LOUIS CITY	0.13	0 - 0.13	UG/L	
ALKALINITY, CaCO3 STABILITY	5/28/2014	ST LOUIS CITY	53.9	41.7 - 53.9	MG/L	
ALKALINITY, TOTAL	1/13/2014	ST LOUIS CITY	203	35 - 203	MG/L	
ALUMINUM	5/28/2014	ST LOUIS CITY	0.0246	0 - 0.0246	MG/L	0.05
CALCIUM	9/24/2014	ST LOUIS CITY	31	23.1 - 31	MG/L	
CHLORIDE	5/28/2014	ST LOUIS CITY	21.5	21 - 21.5	MG/L	250
CHROMIUM, HEX	1/22/2013	ST LOUIS CITY	1.5	0.71 - 1.5	UG/L	
CONDUCTIVITY @ 25 C UMHO/CM	9/25/2014	ST LOUIS CITY	541	393 - 541	UMHO/CM	
HARDNESS, CARBONATE	5/28/2014	ST LOUIS CITY	135	121 - 135	MG/L	
MAGNESIUM	5/28/2014	ST LOUIS CITY	18.8	14.5 - 18.8	MG/L	
MOLYBDENUM, TOTAL	2/3/2014	ST LOUIS CITY	2.08	2.08	UG/L	
NICKEL	5/28/2014	ST LOUIS CITY	0.00144	0.00126 - 0.00144	MG/L	0.1
PH	6/25/2014	ST LOUIS CITY	9.68	8.97 - 9.68	PH	8.5
POTASSIUM	5/28/2014	ST LOUIS CITY	6.35	6.18 - 6.35	MG/L	
SODIUM	5/28/2014	ST LOUIS CITY	53.9	45.3 - 53.9	MG/L	
STRONTIUM	2/3/2014	ST LOUIS CITY	173	173	UG/L	
SULFATE	5/28/2014	ST LOUIS CITY	176	144 - 176	MG/L	250
TDS	5/28/2014	ST LOUIS CITY	342	299 - 342	MG/L	500
TEMPERATURE (CENTIGRADE)	6/25/2014	ST LOUIS CITY	22.2	21 - 22.2	C	
VANADIUM, TOTAL	2/3/2014	ST LOUIS CITY	2.55	2.55	UG/L	

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.